

The latest in FIRE PREVENTION



CHULA VISTA FIRE DEPARTMENT

Bulletin No. 2006-03 • December 5, 2006

Chula Vista Fire Department Requirements for Fire Alarm Control Panels

The City of Chula Vista Fire Department does not accept combination Burglar/Access Control/Fire Alarm panels. Furthermore, these combination panels are not acceptable even when they are used in a dedicated fire alarm design. Acceptable fire alarm panels will be listed for fire alarm use only.

The City of Chula Vista Fire Department does not accept fire alarm panels operating on 12 volts. Acceptable fire alarm panels will operate on 24 volts. (The parallel wiring that is used in 12-volt panels does not allow battery capacity to be supervised.)

Acceptable fire alarm panels will be listed for their proposed use.



JUSTIN GIPSON, FIRE MARSHAL

Fire Department • 447 F Street • (619) 691-5055 • fax (619) 691-5057 • www.chulavistaca.gov